

Addendum to the Landscape Sensitivity Capacity Studies

This addendum lists changes agreed during the consultation period into the Wind and Solar SPG and accompanying Landscape Sensitivity and Capacity Studies

Solar PV Development

- Page 381 – Under Valued Landscapes and Cultural Heritage Assets, last paragraph the following is added “registered parks and gardens, **and landscapes included in the register of Landscapes of Historic Interest in Wales)**”.

Wind Turbine Development

- Page 389 – Under Valued Landscapes and Cultural Heritage Assets, last paragraph the following is added “registered parks and gardens, **and landscapes included in the register of Landscapes of Historic Interest in Wales)**”.
- Page 387 Para 5.11 – Under Micro-siting, insert a new paragraph: para 5.10a The red edge of the site location plan and the representation of the potential swept area(s) should include any allowance being requested by the developer for micro-siting. This will help to ensure that minimum requirements for separation from other turbines, residential properties and vegetation (such as hedgelines), as well as topple distances, will not be compromised by the use of micro-siting allowances.
- Page 387 Para 5.11 – Under Ancillary Infrastructure, the first sentence should read: “Landscape and visual impacts of any ancillary developments, the cumulative landscape and visual effects arising from the combination of turbines and ancillary structures should be minimised by:”